

Technical Note – SunSpec Logging in SolarEdge Inverters

Contents

Technical Note – SunSpec Logging in SolarEdge Inverters.....	1
Version History.....	3
Overview	3
Communication Technologies.....	3
SunSpec Supported Inverters.....	4
Use Cases for MODBUS over RS485.....	4
Physical Connection	4
Single Inverter Connection.....	5
Multiple Inverter Connection.....	5
Use Cases for MODBUS over TCP.....	8
Single Inverter Connection.....	8
Multiple Inverter Connection.....	8
SolarEdge Device Configuration – Using SetApp	11
Modbus over RS485 Configuration	11
MODBUS over TCP Support	12
MODBUS over TCP Configuration	13
SolarEdge Device Configuration – Using the Inverter/Commercial Gateway Display (LCD).....	13
Modbus over RS485 Configuration	13
MODBUS over TCP Support	14
MODBUS over TCP Configuration	14
Register Mapping – Monitoring Data.....	15
Common Model MODBUS Register Mappings	15
Inverter Device Status Values	16
Inverter Model MODBUS Register Mappings	16
Meter Models	17
Meter Device Block.....	18
Meter Event Flag Values	18
MODBUS Register Mappings	18

Appendix A – Supported MODBUS Request Methods27

Appendix B – Response Time Information.....28

Appendix C – Encoding and Decoding 32-bit Values in Modbus29

 32-bit Unsigned Integer (uint32)29

 32-bit Single Precision Floating Point (float32).....29

Revision History

- Version 2.0 (January 2019):
 - Addition of SetApp information
 - Addition of Modbus over TCP option
 - Addition of reference to inverter upgrade procedure
 - Addition of Appendix C – Encoding and Decoding 32-bit Values in Modbus.
- Version 1.0 (2016) – Initial Release

Overview

SolarEdge inverters support reading inverter-level monitoring data directly from the inverter to a local non-SolarEdge device, by implementing the SunSpec open protocol for interoperability between devices in renewable energy systems. This option can be used alongside the connection to the SolarEdge monitoring server. This document describes the connection method and the protocol and configurations needed to implement this feature.


Direct connection to a monitoring device is useful when a network connection is unavailable, when extensive custom data processing is required, or when authorities require direct access to monitoring data.

In many cases, it is possible – and recommended – to employ the direct connection **alongside** a SolarEdge monitoring platform connection. Connection to the monitoring platform enables all the monitoring benefits, primarily:

- Proactive installer maintenance and real time troubleshooting by SolarEdge support, using with the physical mapping available only in the monitoring platform
- Module-level monitoring

Communication Technologies

SolarEdge uses an open, industry-standard communications stack in order to provide efficient messaging between SolarEdge and third-party devices and applications.



The communications stack components are briefly described below.

SunSpec

SunSpec is an application-layer communications protocol designed to achieve interoperability between Distributed Energy Resource (DER) components and smart grid applications.

Modbus

Modbus is a serial communications protocol typically used to connect data collection terminals to a centralized processing unit. SolarEdge products use Modbus to perform SunSpec messaging over two types of physical/link-layer channels:

- **Modbus RTU:** Remote Terminal Unit (RTU) Modbus over a serial RS485 connection
- **Modbus TCP:** Modbus over an Ethernet connection

SolarEdge systems support a single Modbus master only – either single Modbus RTU or single Modbus TCP.

SunSpec Supported Inverters

Depending on their type, SolarEdge devices may be configured in either of the two ways:

- Using SetApp
- Using the LCD

All SolarEdge inverters with SetApp configuration are SunSpec-supported.

SolarEdge inverters with the LCD that have Firmware version 3.xxxx and above only are SunSpec-supported.

► To check the inverter firmware versions (for inverters with the LCD):

1. Short press the LCD light button until reaching the following screen:

```

ID : ##### ##
DSP 1 / 2 : x . x x x x / x . x x x x
CPU : 0 0 0 2 . 0 4 9 6
Country : x x x x x
  
```

2. If required, upgrade to the latest available firmware, as described in https://www.solaredge.com/sites/default/files/upgrading_an_inverter_using_micro_sd_card.pdf.

Use Cases for MODBUS over RS485

This section describes RS485 options to connect the inverter to a non-SolarEdge monitoring device.

Physical Connection

The connection is performed using an RS485 connector with a twisted pair cable. The transmission mode in SolarEdge inverters is set to RTU (binary).

The COM port default properties are: 115200 bps, 8 data bits, no parity, 1 stop bit, no flow control. Baud rate can be changed between 9600bps to 115200bps (supported from CPU version 2.0549).

The RS485 bus can be configured to support connection either to a non-SolarEdge monitoring device or master-slave connection between SolarEdge inverters. Therefore, a slave inverter cannot communicate simultaneously with a master inverter and with a non-SolarEdge monitoring device on the same RS485 bus.

All SolarEdge inverters with SetApp configuration have two built-in RS485 ports. An inverter can act as master on both ports simultaneously.

A Commercial Gateway with LCD can act as master on one of the built-in RS485 ports and on the RS485 Plug-in.


For more information on the RS485 Plug-in, go to:

https://www.solaredge.com/sites/default/files/RS485_expansion_kit_installation_guide.pdf

Single Inverter Connection

Use the RS485 bus for connecting to a non-SolarEdge monitoring device.

Use the Ethernet connection or any of the optional wireless connection options to connect to the SolarEdge monitoring platform.




Multiple Inverter Connection

If a second RS485 port is required to establish connection, use:


- RS485-2 for inverters with SetApp configuration
- RS485-E (requires a RS485 Plug-in) for inverters with an LCD

Connection to a non-SolarEdge monitoring device only (without connection to the monitoring platform)

Option 1 (direct connection) – Use RS485-1 to connect slaves to the master and the master to a non-SolarEdge monitoring device. Every inverter in the RS485 bus should be configured to a different device ID (MODBUS ID).




Option 2 – Use RS485-1 to connect slaves to the master; use either RS485-2 or RS485-E to connect the master to a non-SolarEdge monitoring device. Every inverter in the RS485 bus should be configured to a different device ID (MODBUS ID).




Connection to a non-SolarEdge monitoring device (with connection to the monitoring platform)

Use the RS485 bus for connection to a non-SolarEdge monitoring device. Every inverter in the RS485 bus should be configured to a different device ID (MODBUS ID).

Option 1 (direct connection) – Connect each inverter to the Ethernet router via Ethernet cables.




Option 2 – Connect the Ethernet router to one inverter only.




Connection to the monitoring platform and to a non-SolarEdge monitoring device using a Commercial Gateway

Use the RS485-2 bus for connection to a non-SolarEdge monitoring device. Every inverter connected to the RS485 bus should be configured to a different device ID (MODBUS ID).



If required, use the RS485-E bus for connecting a second chain of inverters.




Use Cases for MODBUS over TCP

This section describes MODBUS over TCP options to connect the inverter to a non-SolarEdge monitoring device.

Single Inverter Connection


Use Ethernet for connecting to a non-SolarEdge monitoring device.



Multiple Inverter Connection

Connection to a non-SolarEdge monitoring device only (without connection to the SolarEdge monitoring platform)


Use Ethernet for connection to a non-SolarEdge monitoring device. Every inverter in the RS485 should be configured to a different device ID (MODBUS ID).




Connection to a non-SolarEdge monitoring device (with connection to the SolarEdge monitoring platform)

Use Ethernet for connection to a non-SolarEdge monitoring device. Every inverter in the RS485 bus should be configured to a different device ID (MODBUS ID).


Option 1 (direct connection) – Connect each inverter to the Ethernet router via Ethernet cables.



Option 2 – Connect the Master only to the Ethernet router via Ethernet cables.




Connect a second chain of the inverters to the Master inverter using RS485-2/RS485-E.




Connection to the SolarEdge monitoring platform and to a non-SolarEdge monitoring device using a Commercial Gateway

Use Ethernet for connection to a non-SolarEdge monitoring device. Every inverter connected to the RS485 bus should be configured to a different device ID (MODBUS ID).



If required, use the RS485-E bus for connecting a second chain of inverters.



SolarEdge Device Configuration – Using SetApp

This section describes how to configure a SolarEdge device (inverter or Commercial Gateway) to be monitored by a non-SolarEdge monitoring device using SetApp.

NOTE

The actual SetApp screens may differ from the ones shown in this document.

To reach the main setup menu, access SetApp and tap **Commissioning** → **Communication**:

Modbus over RS485 Configuration

► To configure the inverters (when used without the Commercial Gateway):

- 1 Under the **Communication** menu, set the following:
 - RS485-1 → Protocol → SunSpec (Non-SE Logger)
 - RS485-1 → Device ID, and enter the MODBUS address (a unique value 1...247). This will set the register C_DeviceAddress.
- 2 If needed, set the baud rate to a preferred value: RS485-1 → Baud rate and enter the rate.

► To configure the inverters and gateway (when used with the Commercial Gateway):

- 1 Inverter configuration: For all inverters, set the following RS485 bus settings under the **Communication** menu:
 - RS485-1 → Protocol → SolarEdge (Slave)
 - RS485-1 → Device ID → [a unique value 1...247]
- 2 Commercial Gateway configuration: Use RS485-1 to connect to the inverters. RS485-1 bus configuration is as follows:
 - Communication → RS485-1 Conf → Device Type → SolarEdge
 - Communication → RS485-1 Conf → Protocol → Master
 - Communication → RS485-1 Conf → Slave Detect

The Commercial Gateway should report the correct number of slaves. If it does not, verify the connections and terminations.
- 3 Use RS485-2 to connect to the non-SolarEdge monitoring device. RS485-2 bus configuration is as follows:
 - Communication → RS485-2 → Protocol → SunSpec (Non-SE Logger)

The Commercial Gateway device ID is irrelevant for the communication but needs to be set to one other than that set for the inverters.

- Communication → RS485-2 → Device ID → [use one of the higher IDs (e.g. 247) to make sure it is out of scope]
- The default baud rate is 115200bps. If a different baud rate is required, select: **Communication → RS485-2 Conf → Baud Rate**

4 Make sure the device ID of the non-SolarEdge monitoring device is different from all other device IDs configured in the inverters and gateways.

5 Connect the Commercial Gateway to the Ethernet and configure:

- Communication → Server → LAN
- Communication → LAN Conf → Set DHCP → [Select Enable for DHCP or Disable for static IP configuration]
- For Static DHCP setting, configure as follows:
- Communication → LAN Conf → Set IP → [Set inverters' IP]
- Communication → LAN Conf → Set Mask → [Set inverters' subnet mask]
- Communication → LAN Conf → Set Gateway → [Set inverters' gateway]
- Communication → LAN Conf → Set DNS → [Set inverters' DNS]

6 If Ethernet is connected to the server, select **Commissioning → Status** and verify that S_OK is displayed under the main menu:

solar edge		
Status		
Inverter		
SN 07318000C		
Power	Voltage	Frequency
100kW	277 V	60.9 Hz
P_OK: 138 of 141 Optimizers Connected		S_OK Server Connected (LAN)
Status		Switch
Production		ON
CosPhi	Limit	Country
1.00	No Limit	Netherlands
Voltage	Temp	Fan
1.0	20 C	OK
Commissioning		

MODBUS over TCP Support

MODBUS/TCP uses the Ethernet media in physical layers to carry the MODBUS message handling structure and can support a large number of devices in one network; it is easier to integrate into the Local Area Network (LAN) of a company, so it is the choice of more and more customers.

Here, it is used for remote 3rd party monitoring and control. MODBUS TCP is agnostic of the server connection. It works only over LAN. When configured, MODBUS TCP does not initiate a connection - the server waits for a client to connect. Only one connection is supported.

**NOTE**

MODBUS TCP function is disabled by default. When enabled, it supports TCP port 1502 by default. Port number can be reconfigured.

MODBUS over TCP Configuration

► To setup MODBUS TCP:

- 1 Select Communication → Modbus TCP → Enable. A new Port menu is added to the screen (the default port is 1502)
- 2 To modify the TCP port, select **Port**, set the port number and tap **Done**.

**NOTE**

The default device ID of the inverter connected to the Ethernet is 1.

**NOTE**

The TCP server idle time is 2 minutes. In order to leave the connection open, the request should be made within 2 minutes. The connection can remain open without any MODBUS requests.

SolarEdge Device Configuration – Using the Inverter/Commercial Gateway Display (LCD)

This section describes how to configure a SolarEdge device (inverter or Commercial Gateway) to be monitored by a non-SolarEdge monitoring device using the LCD. To reach the main setup menu, follow the instructions in the *Installation Guide* of the specific SolarEdge device.

Modbus over RS485 Configuration

► To configure the inverters (when used without the Commercial Gateway):

- 1 Under the Communication menu, set the following:
 - Communication → Server → Select any server connection, except for RS485 (if the inverter is *not* connected to the SolarEdge monitoring platform, select **None**).
 - Communication → RS485-1 Conf
 - RS485-1 Conf → Device Type → Non-SE Logger
 - RS485-1 Conf → Protocol → SunSpec
 - RS485-1 Conf → Device ID and enter the MODBUS address (a unique value 1...247). This will set the register C_DeviceAddress.
- 2 If needed, set the baud rate to a preferred value: RS485-1 Conf → Baud rate and enter the rate.

► To configure the inverter (when used with the Commercial Gateway):

- 1 Inverters configuration: For all inverters, set the following RS485 bus settings:
 - Communication → RS485-1 Conf → Device Type → SolarEdge
 - Communication → RS485-1 Conf → Protocol → Slave
 - Communication → RS485-1 Conf → Device ID → [a unique value 1...247]
- 2 Commercial Gateway configuration: Use RS485-1 to connect to the inverters. RS485-1 bus configuration is as follows:

- Communication → RS485-1 Conf → Device Type → SolarEdge
- Communication → RS485-1 Conf → Protocol → Master
- Communication → RS485-1 Conf → Slave Detect

The Commercial Gateway should report the correct number of slaves. If it does not, verify the connections and terminations.

3 Use RS485-2 to connect to the non-SolarEdge monitoring device. RS485-2 bus configuration is as follows:

- Communication → RS485-2 Conf → Device Type → Non-SE Logger
- Communication → RS485-2 Conf → Protocol → SunSpec

The Commercial Gateway device ID is irrelevant for the communication but needs to be set to one other than the that set for the inverters.

- Communication → RS485-2 Conf → Device ID → [use one of the higher ID's (e.g. 247) to make sure it is out of scope]
- The default baud rate is 115200bps. If a different baud rate is required, select: Communication → RS485-2 Conf → Baud Rate

4 Make sure the device ID of the non-SolarEdge monitoring device is different from all other device IDs configured in the inverters and gateways.

5 Connect the Commercial Gateway to the Ethernet and configure:

- Communication → Server → LAN
- Communication → LAN Conf → Set DHCP → [Select Enable for DHCP or Disable for static IP configuration]
- For Static DHCP setting, configure as follows:
- Communication → LAN Conf → Set IP → [Set inverters' IP]
- Communication → LAN Conf → Set Mask → [Set inverters' subnet mask]
- Communication → LAN Conf → Set Gateway → [Set inverters' gateway]
- Communication → LAN Conf → Set DNS → [Set inverters' DNS]

6 If Ethernet is connected to the server, verify that the LCD panel displays <S_OK>.

7 Verify that the LCD panel of all inverters is <S_OK>.

MODBUS over TCP Support

MODBUS/TCP uses the Ethernet media in physical layers to carry the MODBUS message handling structure and can support a large number of devices in one network; it is easier to integrate into the Local Area Network (LAN) of a company, so it is the choice of more and more customers.

Here, it is used for remote 3rd party monitoring and control. MODBUS TCP is agnostic of the server connection. It works only over LAN. When configured, MODBUS TCP does not initiate a connection. The server waits for a client to connect. Only one connection is supported.



NOTE

MODBUS TCP function– is disabled by default. When enabled, it supports TCP port 502 by default. Port number can be reconfigured.

MODBUS over TCP Configuration

► To setup MODBUS TCP:

- Select **Communication** → **LAN Conf** → **Modbus TCP** (the default port is 502).
- To modify the TCP port, select **Modbus TCP** → **TCP Port**, set the port number and long-press Enter.

**NOTE**

The default device ID of the inverter connected to the Ethernet is 1.

When the MODBUS TCP feature is enabled, the following status screen is shown:

```

M o d b u s   T C P :   < s t a t u s >
I P : 1 9 2 . 1 6 8 . 1 . 2 1 0
P o r t : 5 0 2
< e r r o r   m e s s a g e >
  
```

- Status:

- **Init** – Initializing server – This state only occurs after the first configuration until it reaches the ready status. This activity lasts about 10sec.
- **Ready** – The server is up and waiting for a client to connect.
- **Connected** – The client is connected.
- **Failed** – The server is unable to accept clients (see error message).

- Error messages:

- **Disconnected** – The Ethernet cable is not connected
- **Gateway Ping Failed.** – A ping to the 1st router failed
- **No IP** - Either no DHCP configuration or static IP config (no DHCP server that assigned an IP address) or need to define a static IP.

**NOTE**

The TCP server idle time is 2 minutes. In order to leave the connection open, the request should be made within 2 minutes. The connection can remain open without any MODBUS requests.

Register Mapping – Monitoring Data

This section describes the registers mapping for the inverter monitoring data (read-only MODBUS protocol data). The SolarEdge inverter mapping for monitoring data is based on the open protocol managed by SunSpec: SunSpec Alliance Interoperability Specification – Inverter Models v1.0. Refer to the *SunSpec Alliance Interoperability Specification – Common Models (Elements)* document for a detailed description of the protocol.

The register mapping can be downloaded from the SunSpec Alliance web page: <http://www.sunspec.org/>.

SolarEdge inverters support Sunspec module ID 101, 102¹ and 103 register mappings.

Common Model MODBUS Register Mappings

The base Register Common Block is set to 40001 (MODBUS PLC address [base 1]) or 40000 (MODBUS Protocol Address [base 0]).

All parameters are defined as in the SunSpec Common block definition, except for the **C_Options** register, which is set to NOT_IMPLEMENTED.

C_Manufacturer is set to SolarEdge.

C_Model is set to the appropriate inverter model, e.g. SE5000.

C_Version contains the CPU software version with leading zeroes, e.g. 0002.0611.

C_SerialNumber contains the inverter serial number.

C_DeviceAddress is the device MODBUS ID.

¹ Supported only in split-phase configurations (Japanese grid and 240V grid in North America)

Address	Size	Name	Type	Description
40001	2	C_SunSpec_ID	uint32	Value = "SunS" (0x53756e53). Uniquely identifies this as a SunSpec MODBUS Map
40003	1	C_SunSpec_DID	uint16	Value = 0x0001. Uniquely identifies this as a SunSpec Common Model Block
40004	1	C_SunSpec_Length	uint16	65 = Length of block in 16-bit registers
40005	16	C_Manufacturer	String(32)	Value Registered with SunSpec = "SolarEdge "
40021	16	C_Model	String(32)	SolarEdge Specific Value
40045	8	C_Version	String(16)	SolarEdge Specific Value
40053	16	C_SerialNumber	String(32)	SolarEdge Unique Value
40069	1	C_DeviceAddress	uint16	MODBUS Unit ID

Inverter Device Status Values

The following **I_Status_ xxxx** values are supported:

Parameter	Value	Description
I_STATUS_OFF	1	Off
I_STATUS_SLEEPING	2	Sleeping (auto-shutdown) – Night mode
I_STATUS_STARTING	3	Grid Monitoring/wake-up
I_STATUS_MPPT	4	Inverter is ON and producing power
I_STATUS_THROTTLED	5	Production (curtailed)
I_STATUS_SHUTTING_DOWN	6	Shutting down
I_STATUS_FAULT	7	Fault
I_STATUS_STANDBY	8	Maintenance/setup

Inverter Model MODBUS Register Mappings

The following table lists the supported MODBUS register values.

Unsupported values are indicated by the NOT_IMPLEMENTED value.

DC values are not supported for three phase inverters with synergy technology.

The base register of the Device Specific block is set to 40070 (MODBUS PLC address [base 1]), or 40069 (MODBUS Protocol Address [base 0]).

- **acc32** is uint32 that should always increase. Its value is in the Range of 0 ...4294967295.
- **Scale Factors**

As an alternative to floating point format, values are represented by Integer values with a signed scale factor applied. The scale factor explicitly shifts the decimal point to left (negative value) or to the right (positive value).

For example, a value "Value" may have an associated value "Value_SF"

Value = "Value" * 10^{Value_SF} for example:

For "Value" = 2071 and "Value_SF" = -2 Value = 2071*10⁻² = 20.71

For "Value" = 2071 and "Value_SF" = 2 Value = 2071*10² = 207100

Address	Size	Name	Type	Units	Description
40070	1	C_SunSpec_DID	uint16		101 = single phase 102 = split phase ¹ 103 = three phase
40071	1	C_SunSpec_Length	uint16	Registers	50 = Length of model block
40072	1	I_AC_Current	uint16	Amps	AC Total Current value
40073	1	I_AC_CurrentA	uint16	Amps	AC Phase A Current value

Address	Size	Name	Type	Units	Description
40074	1	I_AC_CurrentB	uint16	Amps	AC Phase B Current value
40075	1	I_AC_CurrentC	uint16	Amps	AC Phase C Current value
40076	1	I_AC_Current_SF	int16		AC Current scale factor
40077	1	I_AC_VoltageAB	uint16	Volts	AC Voltage Phase AB value
40078	1	I_AC_VoltageBC	uint16	Volts	AC Voltage Phase BC value
40079	1	I_AC_VoltageCA	uint16	Volts	AC Voltage Phase CA value
40080	1	I_AC_VoltageAN ²	uint16	Volts	AC Voltage Phase A to N value
40081	1	I_AC_VoltageBN ¹	uint16	Volts	AC Voltage Phase B to N value
40082	1	I_AC_VoltageCN ¹	uint16	Volts	AC Voltage Phase C to N value
40083	1	I_AC_Voltage_SF	int16		AC Voltage scale factor
40084	1	I_AC_Power	int16	Watts	AC Power value
40085	1	I_AC_Power_SF	int16		AC Power scale factor
40086	1	I_AC_Frequency	uint16	Hertz	AC Frequency value
40087	1	I_AC_Frequency_SF	int16		Scale factor
40088	1	I_AC_VA	int16	VA	Apparent Power
40089	1	I_AC_VA_SF	int16		Scale factor
40090	1	I_AC_VAR	int16	VAR	Reactive Power
40091	1	I_AC_VAR_SF	int16		Scale factor
40092	1	I_AC_PF	int16	%	Power Factor
40093	1	I_AC_PF_SF	int16		Scale factor
40094	2	I_AC_Energy_WH	acc32	WattHours	AC Lifetime Energy production
40096	1	I_AC_Energy_WH_SF	uint16		Scale factor
40097	1	I_DC_Current	uint16	Amps	DC Current value
40098	1	I_DC_Current_SF	int16		Scale factor
40099	1	I_DC_Voltage	uint16	Volts	DC Voltage value
40100	1	I_DC_Voltage_SF	int16		Scale factor
40101	1	I_DC_Power	int16	Watts	DC Power value
40102	1	I_DC_Power_SF	int16		Scale factor
40104	1	I_Temp_Sink	int16	Degrees C	Heat Sink Temperature
40107	1	I_Temp_SF	int16		Scale factor
40108	1	I_Status	uint16		Operating State
40109	1	I_Status_Vendor	uint16		Vendor-defined operating state and error codes. For error description, meaning and troubleshooting, refer to the SolarEdge Installation Guide.

Meter Models

The SunSpec Alliance Interoperability Specification describes the data models and MODBUS register mappings for meter devices used in Renewable Energy systems. This section defines the models for:

- Single Phase Meter
- Split Phase Meter
- WYE (4-wire) Meter
- Delta (3-wire) Meter

² Supported only in split-phase configurations (Japanese grid and 240V grid in North America).

Meter Device Block

The following data elements are provided to describe meters.

- **C_SunSpec_DID** – A well-known value that uniquely identifies this block as a meter block. (4) for single phase meters and (5) for three phase meter types.
- **C_SunSpec_Length** – The length of the meter block in registers.
- **M_AC_xxxx**– Meter AC values.
- **M_Exported_xxxx**– Meter Exported Energy values
- **M_Imported_xxxx**– Meter Imported Energy values

Energy value

The energy value is represented by a 32 bit unsigned integer accumulator with a scale factor. Values for import and export are provided. Unsupported or invalid accumulators may return 0x00000000. Power signs and Energy quadrants are per IEEE 1459-2000.

Meter Event Flag Values

The SunSpec Common Elements defines a C_Event value. The meter specific flags are defined here.

C_Event Value	Flag	Description
M_EVENT_Power_Failure	0x00000004	Loss of power or phase
M_EVENT_Under_Voltage	0x00000008	Voltage below threshold (Phase Loss)
M_EVENT_Low_PF	0x00000010	Power Factor below threshold (can indicate miss-associated voltage and current inputs in three phase systems)
M_EVENT_Over_Current	0x00000020	Current Input over threshold (out of measurement range)
M_EVENT_Over_Voltage	0x00000040	Voltage Input over threshold (out of measurement range)
M_EVENT_Missing_Sensor	0x00000080	Sensor not connected
M_EVENT_Reserved1	0x00000100	Reserved for future
M_EVENT_Reserved2	0x00000200	Reserved for future
M_EVENT_Reserved3	0x00000400	Reserved for future
M_EVENT_Reserved4	0x00000800	Reserved for future
M_EVENT_Reserved5	0x00001000	Reserved for future
M_EVENT_Reserved6	0x00002000	Reserved for future
M_EVENT_Reserved7	0x00004000	Reserved for future
M_EVENT_Reserved8	0x00008000	Reserved for future
M_EVENT_OEM1-15	0x7FFF000	Reserved for OEMs

MODBUS Register Mappings

Meter Model – MODBUS Mapping

This map supports single, split, wye, and delta meter connections in a single map as proper subsets. The connection type is distinguished by the C_SunSpec_DID. Registers that are not applicable to a meter class return the unsupported value. (e.g. Single Phase meters will support only summary and phase A values).

Meters base address:

- 1st meter – 40000 + 121
- 2nd meter – 40000 + 295
- 3rd meter – 40000 + 469


NOTE

Only enabled meters are readable, i.e. if meter 1 and 3 are enabled, they are readable as 1st meter and 2nd meter (and the 3rd meter isn't readable). The meter type can be read from the Common block Options field (the same strings that we use in the menus).

Meter 1

Address	Size	Name	Type	Units	Description
Common Block					
40121	1	C_SunSpec_DID	uint16	N/A	Value = 0x0001. Uniquely identifies this as a SunSpec Common Model Block
40122	1	C_SunSpec_Length	uint16	N/A	65 = Length of block in 16-bit registers
40123	16	C_Manufacturer	String(32)	N/A	Meter manufacturer
40139	16	C_Model	String(32)	N/A	Meter model
40155	8	C_Option	String(16)	N/A	Export + Import, Production, consumption,
40163	8	C_Version	String(16)	N/A	Meter version
40171	16	C_SerialNumber	String(32)	N/A	Meter SN
40187	1	C_DeviceAddress	uint16	N/A	Inverter Modbus ID
Identification					
40188	1	C_SunSpec_DID	uint16	N/A	Well-known value. Uniquely identifies this as a SunSpecMODBUS Map: Single Phase (AN or AB) Meter (201) Split Single Phase (ABN) Meter (202) Wye-Connect Three Phase (ABCN) Meter (203) Delta-Connect Three Phase (ABC) Meter(204)
40189	1	C_SunSpec_Length	uint16	Registers	Length of meter model block
Current					
40190	1	M_AC_Current	int16	Amps	AC Current (sum of active phases)
40191	1	M_AC_Current_A	int16	Amps	Phase A AC Current
40192	1	M_AC_Current_B	int16	Amps	Phase B AC Current
40193	1	M_AC_Current_C	int16	Amps	Phase C AC Current
40194	1	M_AC_Current_SF	int16	SF	AC Current Scale Factor
Voltage					
Line to Neutral Voltage					
40195	1	M_AC_Voltage_L N	int16	Volts	Line to Neutral AC Voltage (average of active phases)
40196	1	M_AC_Voltage_A N	int16	Volts	Phase A to Neutral AC Voltage
40197	1	M_AC_Voltage_B N	int16	Volts	Phase B to Neutral AC Voltage
40198	1	M_AC_Voltage_C N	int16	Volts	Phase C to Neutral AC Voltage
Line to Line Voltage					
40199	1	M_AC_Voltage_L L	int16	Volts	Line to Line AC Voltage (average of active phases)
40200	1	M_AC_Voltage_A B	int16	Volts	Phase A to Phase B AC Voltage
40201	1	M_AC_Voltage_B C	int16	Volts	Phase B to Phase C AC Voltage
40202	1	M_AC_Voltage_C A	int16	Volts	Phase C to Phase A AC Voltage
40203	1	M_AC_Voltage_SF	int16	SF	AC Voltage Scale Factor
Frequency					
40204	1	M_AC_Freq	int16	Hertz	AC Frequency
40205	1	M_AC_Freq_SF	int16	SF	AC Frequency Scale Factor
Power					
Real Power					

Address	Size	Name	Type	Units	Description
40206	1	M_AC_Power	int16	Watts	Total Real Power (sum of active phases)
40207	1	M_AC_Power_A	int16	Watts	Phase A AC Real Power
40208	1	M_AC_Power_B	int16	Watts	Phase B AC Real Power
40209	1	M_AC_Power_C	int16	Watts	Phase C AC Real Power
40210	1	M_AC_Power_SF	int16	SF	AC Real Power Scale Factor
Apparent Power					
40211	1	M_AC_VA	int16	Volt- Amps	Total AC Apparent Power (sum of active phases)
40212	1	M_AC_VA_A	int16	Volt- Amps	Phase A AC Apparent Power
40213	1	M_AC_VA_B	int16	Volt- Amps	Phase B AC Apparent Power
40214	1	M_AC_VA_C	int16	Volt- Amps	Phase C AC Apparent Power
40215	1	M_AC_VA_SF	int16	SF	AC Apparent Power Scale Factor
Reactive Power					
40216	1	M_AC_VAR	int16	VAR	Total AC Reactive Power (sum of active phases)
40217	1	M_AC_VAR_A	int16	VAR	Phase A AC Reactive Power
40218	1	M_AC_VAR_B	int16	VAR	Phase B AC Reactive Power
40219	1	M_AC_VAR_C	int16	VAR	Phase C AC Reactive Power
40220	1	M_AC_VAR_SF	int16	SF	AC Reactive Power Scale Factor
Power Factor					
40221	1	M_AC_PF	int16	%	Average Power Factor (average of active phases)
40222	1	M_AC_PF_A	int16	%	Phase A Power Factor
40223	1	M_AC_PF_B	int16	%	Phase B Power Factor
40224	1	M_AC_PF_C	int16	%	Phase C Power Factor
40225	1	M_AC_PF_SF	int16	SF	AC Power Factor Scale Factor
Accumulated Energy					
Real Energy					
40226	2	M_Exported	uint32	Watt- hours	Total Exported Real Energy
40228	2	M_Exported_A	uint32	Watt- hours	Phase A Exported Real Energy
40230	2	M_Exported_B	uint32	Watt- hours	Phase B Exported Real Energy
40232	2	M_Exported_C	uint32	Watt- hours	Phase C Exported Real Energy
40234	2	M_Imported	uint32	Watt- hours	Total Imported Real Energy
40236	2	M_Imported_A	uint32	Watt- hours	Phase A Imported Real Energy
40238	2	M_Imported_B	uint32	Watt- hours	Phase B Imported Real Energy
40240	2	M_Imported_C	uint32	Watt- hours	Phase C Imported Real Energy
40242	1	M_Energy_W_SF	int16	SF	Real Energy Scale Factor
Apparent Energy					
40243	2	M_Exported_VA	uint32	VA-hours	Total Exported Apparent Energy
40245	2	M_Exported_VA_A	uint32	VA-hours	Phase A Exported Apparent Energy
40247	2	M_Exported_VA_B	uint32	VA-hours	Phase B Exported Apparent Energy
40249	2	M_Exported_VA_C	uint32	VA-hours	Phase C Exported Apparent Energy
40251	2	M_Imported_VA	uint32	VA-hours	Total Imported Apparent Energy
40253	2	M_Imported_VA_A	uint32	VA-hours	Phase A Imported Apparent Energy
40255	2	M_Imported_VA_B	uint32	VA-hours	Phase B Imported Apparent Energy
40257	2	M_Imported_VA_C	uint32	VA-hours	Phase C Imported Apparent Energy
40259	1	M_Energy_VA_SF	int16	SF	Apparent Energy Scale Factor

Address	Size	Name	Type	Units	Description
Reactive Energy					
40260	2	M_Import_VARh_Q1	uint32	VAR-hours	Quadrant 1: Total Imported Reactive Energy
40262	2	M_Import_VARh_Q1A	uint32	VAR-hours	Phase A - Quadrant 1: Imported Reactive Energy
40264	2	M_Import_VARh_Q1B	uint32	VAR-hours	Phase B- Quadrant 1: Imported Reactive Energy
40266	2	M_Import_VARh_Q1C	uint32	VAR-hours	Phase C- Quadrant 1: Imported Reactive Energy
40268	2	M_Import_VARh_Q2	uint32	VAR-hours	Quadrant 2: Total Imported Reactive Energy
40270	2	M_Import_VARh_Q2A	uint32	VAR-hours	Phase A - Quadrant 2: Imported Reactive Energy
40272	2	M_Import_VARh_Q2B	uint32	VAR-hours	Phase B- Quadrant 2: Imported Reactive Energy
40274	2	M_Import_VARh_Q2C	uint32	VAR-hours	Phase C- Quadrant 2: Imported Reactive Energy
40276	2	M_Export_VARh_Q3	uint32	VAR-hours	Quadrant 3: Total Exported Reactive Energy
40278	2	M_Export_VARh_Q3A	uint32	VAR-hours	Phase A - Quadrant 3: Exported Reactive Energy
40280	2	M_Export_VARh_Q3B	uint32	VAR-hours	Phase B- Quadrant 3: Exported Reactive Energy
40282	2	M_Export_VARh_Q3C	uint32	VAR-hours	Phase C- Quadrant 3: Exported Reactive Energy
40284	2	M_Export_VARh_Q4	uint32	VAR-hours	Quadrant 4: Total Exported Reactive Energy
40286	2	M_Export_VARh_Q4A	uint32	VAR-hours	Phase A - Quadrant 4: Exported Reactive Energy
40288	2	M_Export_VARh_Q4B	uint32	VAR-hours	Phase B- Quadrant 4: Exported Reactive Energy
40290	2	M_Export_VARh_Q4C	uint32	VAR-hours	Phase C- Quadrant 4: Exported Reactive Energy
40292	1	M_Energy_VAR_SF	int16	SF	Reactive Energy Scale Factor
Events					
40293	2	M_Events	uint32	Flags	See M_EVENT_flags. 0 = nts.

Meter 2

Address	Size	Name	Type	Units	Description
Common Block					
40295	1	C_SunSpec_DID	uint16	N/A	Value = 0x0001. Uniquely identifies this as a SunSpec Common Model Block
40296	1	C_SunSpec_Length	uint16	N/A	65 = Length of block in 16-bit registers
40297	16	C_Manufacturer	String(32)	N/A	Meter manufacturer
40313	16	C_Model	String(32)	N/A	Meter model
40329	8	C_Option	String(16)	N/A	Export+Import, Production,consumption,
40337	8	C_Version	String(16)	N/A	Meter version
40345	16	C_SerialNumber	String(32)	N/A	Meter SN
40361	1	C_DeviceAddress	uint16	N/A	Inverter Modbus ID
Identification					
40362	1	C_SunSpec_DID	uint16	N/A	Well-known value. Uniquely identifies this as a SunSpecMODBUS Map: Single Phase (AN or AB) Meter (201) Split Single Phase (ABN) Meter (202) Wye-Connect Three Phase (ABCN) Meter (203) Delta-Connect Three Phase (ABC) Meter(204)
40363	1	C_SunSpec_Length	uint16	Registers	Length of meter model block
Current					
40364	1	M_AC_Current	int16	Amps	AC Current (sum of active phases)
40365	1	M_AC_Current_A	int16	Amps	Phase A AC Current

40366	1	M_AC_Current_B	int16	Amps	Phase B AC Current
40367	1	M_AC_Current_C	int16	Amps	Phase C AC Current
40368	1	M_AC_Current_SF	int16	SF	AC Current Scale Factor
Voltage					
Line to Neutral Voltage					
40369	1	M_AC_Voltage_L N	int16	Volts	Line to Neutral AC Voltage (average of active phases)
40370	1	M_AC_Voltage_A N	int16	Volts	Phase A to Neutral AC Voltage
40371	1	M_AC_Voltage_B N	int16	Volts	Phase B to Neutral AC Voltage
40372	1	M_AC_Voltage_C N	int16	Volts	Phase C to Neutral AC Voltage
Line to Line Voltage					
40373	1	M_AC_Voltage_L L	int16	Volts	Line to Line AC Voltage (average of active phases)
40374	1	M_AC_Voltage_A B	int16	Volts	Phase A to Phase B AC Voltage
40375	1	M_AC_Voltage_B C	int16	Volts	Phase B to Phase C AC Voltage
40376	1	M_AC_Voltage_C A	int16	Volts	Phase C to Phase A AC Voltage
40377	1	M_AC_Voltage_SF	int16	SF	AC Voltage Scale Factor
Frequency					
40378	1	M_AC_Freq	int16	Hertz	AC Frequency
40379	1	M_AC_Freq_SF	int16	SF	AC Frequency Scale Factor
Power					
Real Power					
40380	1	M_AC_Power	int16	Watts	Total Real Power (sum of active phases)
40381	1	M_AC_Power_A	int16	Watts	Phase A AC Real Power
40382	1	M_AC_Power_B	int16	Watts	Phase B AC Real Power
40383	1	M_AC_Power_C	int16	Watts	Phase C AC Real Power
40384	1	M_AC_Power_SF	int16	SF	AC Real Power Scale Factor
Apparent Power					
40385	1	M_AC_VA	int16	Volt- Amps	Total AC Apparent Power (sum of active phases)
40386	1	M_AC_VA_A	int16	Volt- Amps	Phase A AC Apparent Power
40387	1	M_AC_VA_B	int16	Volt- Amps	Phase B AC Apparent Power
40388	1	M_AC_VA_C	int16	Volt- Amps	Phase C AC Apparent Power
40389	1	M_AC_VA_SF	int16	SF	AC Apparent Power Scale Factor
Reactive Power					
40390	1	M_AC_VAR	int16	VAR	Total AC Reactive Power(sum of active phases)
40391	1	M_AC_VAR_A	int16	VAR	Phase A AC Reactive Power
40392	1	M_AC_VAR_B	int16	VAR	Phase B AC Reactive Power
40393	1	M_AC_VAR_C	int16	VAR	Phase C AC Reactive Power
40394	1	M_AC_VAR_SF	int16	SF	AC Reactive Power Scale Factor
Power Factor					
40395	1	M_AC_PF	int16	%	Average Power Factor (average of active phases)
40396	1	M_AC_PF_A	int16	%	Phase A Power Factor
40397	1	M_AC_PF_B	int16	%	Phase B Power Factor
40398	1	M_AC_PF_C	int16	%	Phase C Power Factor
40399	1	M_AC_PF_SF	int16	SF	AC Power Factor Scale Factor

Accumulated Energy					
Real Energy					
40400	2	M_Exported	uint32	Watt- hours	Total Exported Real Energy
40402	2	M_Exported_A	uint32	Watt- hours	Phase A Exported Real Energy
40404	2	M_Exported_B	uint32	Watt- hours	Phase B Exported Real Energy
40406	2	M_Exported_C	uint32	Watt- hours	Phase C Exported Real Energy
40408	2	M_Imported	uint32	Watt- hours	Total Imported Real Energy
40410	2	M_Imported_A	uint32	Watt- hours	Phase A Imported Real Energy
40412	2	M_Imported_B	uint32	Watt- hours	Phase B Imported Real Energy
40414	2	M_Imported_C	uint32	Watt- hours	Phase C Imported Real Energy
40416	1	M_Energy_W_SF	int16	SF	Real Energy Scale Factor
Apparent Energy					
40417	2	M_Exported_VA	uint32	VA-hours	Total Exported Apparent Energy
40419	2	M_Exported_VA_A	uint32	VA-hours	Phase A Exported Apparent Energy
40421	2	M_Exported_VA_B	uint32	VA-hours	Phase B Exported Apparent Energy
40423	2	M_Exported_VA_C	uint32	VA-hours	Phase C Exported Apparent Energy
40425	2	M_Imported_VA	uint32	VA-hours	Total Imported Apparent Energy
40427	2	M_Imported_VA_A	uint32	VA-hours	Phase A Imported Apparent Energy
40429	2	M_Imported_VA_B	uint32	VA-hours	Phase B Imported Apparent Energy
40431	2	M_Imported_VA_C	uint32	VA-hours	Phase C Imported Apparent Energy
40433	1	M_Energy_VA_SF	int16	SF	Apparent Energy Scale Factor
Reactive Energy					
40434	2	M_Import_VARh_Q1	uint32	VAR-hours	Quadrant 1: Total Imported Reactive Energy
40436	2	M_Import_VARh_Q1A	uint32	VAR-hours	Phase A - Quadrant 1: Imported Reactive Energy
40438	2	M_Import_VARh_Q1B	uint32	VAR-hours	Phase B- Quadrant 1: Imported Reactive Energy
40440	2	M_Import_VARh_Q1C	uint32	VAR-hours	Phase C- Quadrant 1: Imported Reactive Energy
40442	2	M_Import_VARh_Q2	uint32	VAR-hours	Quadrant 2: Total Imported Reactive Energy
40444	2	M_Import_VARh_Q2A	uint32	VAR-hours	Phase A - Quadrant 2: Imported Reactive Energy
40446	2	M_Import_VARh_Q2B	uint32	VAR-hours	Phase B- Quadrant 2: Imported Reactive Energy
40448	2	M_Import_VARh_Q2C	uint32	VAR-hours	Phase C- Quadrant 2: Imported Reactive Energy
40450	2	M_Export_VARh_Q3	uint32	VAR-hours	Quadrant 3: Total Exported Reactive Energy
40452	2	M_Export_VARh_Q3A	uint32	VAR-hours	Phase A - Quadrant 3: Exported Reactive Energy
40454	2	M_Export_VARh_Q3B	uint32	VAR-hours	Phase B- Quadrant 3: Exported Reactive Energy
40456	2	M_Export_VARh_Q3C	uint32	VAR-hours	Phase C- Quadrant 3: Exported Reactive Energy
40458	2	M_Export_VARh_Q4	uint32	VAR-hours	Quadrant 4: Total Exported Reactive Energy
40460	2	M_Export_VARh_Q4A	uint32	VAR-hours	Phase A - Quadrant 4: Exported Reactive Energy
40462	2	M_Export_VARh_Q4B	uint32	VAR-hours	Phase B- Quadrant 4: Exported Reactive Energy
40464	2	M_Export_VARh_Q4C	uint32	VAR-hours	Phase C- Quadrant 4: Exported Reactive Energy
40466	1	M_Energy_VAR_SF	int16	SF	Reactive Energy Scale Factor
Events					
40467	2	M_Events	uint32	Flags	See M_EVENT_flags. 0 = nts.

Meter 3

Address	Size	Name	Type	Units	Description
Common Block					
40469	1	C_SunSpec_DID	uint16	N/A	Value = 0x0001. Uniquely identifies this as a SunSpec Common Model Block
40470	1	C_SunSpec_Length	uint16	N/A	65 = Length of block in 16-bit registers
40472	16	C_Manufacturer	String(32)	N/A	Meter manufacturer
40488	16	C_Model	String(32)	N/A	Meter model
40504	8	C_Option	String(16)	N/A	Export+Import, Production,consumption,
40512	8	C_Version	String(16)	N/A	Meter version
40520	16	C_SerialNumber	String(32)	N/A	Meter SN
40536	1	C_DeviceAddress	uint16	N/A	Inverter Modbus ID
Identification					
40537	1	C_SunSpec_DID	uint16	N/A	Well-known value. Uniquely identifies this as a SunSpecMODBUS Map: Single Phase (AN or AB) Meter (201) Split Single Phase (ABN) Meter (202) Wye-Connect Three Phase (ABCN) Meter (203) Delta-Connect Three Phase (ABC) Meter(204)
40538	1	C_SunSpec_Length	uint16	Registers	Length of meter model block
Current					
40539	1	M_AC_Current	int16	Amps	AC Current (sum of active phases)
40540	1	M_AC_Current_A	int16	Amps	Phase A AC Current
40541	1	M_AC_Current_B	int16	Amps	Phase B AC Current
40542	1	M_AC_Current_C	int16	Amps	Phase C AC Current
40543	1	M_AC_Current_SF	int16	SF	AC Current Scale Factor
Voltage					
Line to Neutral Voltage					
40544	1	M_AC_Voltage_L N	int16	Volts	Line to Neutral AC Voltage (average of active phases)
40545	1	M_AC_Voltage_A N	int16	Volts	Phase A to Neutral AC Voltage
40546	1	M_AC_Voltage_B N	int16	Volts	Phase B to Neutral AC Voltage
40547	1	M_AC_Voltage_C N	int16	Volts	Phase C to Neutral AC Voltage
Line to Line Voltage					
40548	1	M_AC_Voltage_L L	int16	Volts	Line to Line AC Voltage (average of active phases)
40549	1	M_AC_Voltage_A B	int16	Volts	Phase A to Phase B AC Voltage
40550	1	M_AC_Voltage_B C	int16	Volts	Phase B to Phase C AC Voltage
40551	1	M_AC_Voltage_C A	int16	Volts	Phase C to Phase A AC Voltage
40552	1	M_AC_Voltage_SF	int16	SF	AC Voltage Scale Factor
Frequency					
40553	1	M_AC_Freq	int16	Hertz	AC Frequency
40554	1	M_AC_Freq_SF	int16	SF	AC Frequency Scale Factor
Power					
Real Power					
40555	1	M_AC_Power	int16	Watts	Total Real Power (sum of active phases)
40556	1	M_AC_Power_A	int16	Watts	Phase A AC Real Power
40557	1	M_AC_Power_B	int16	Watts	Phase B AC Real Power
40558	1	M_AC_Power_C	int16	Watts	Phase C AC Real Power

40559	1	M_AC_Power_SF	int16	SF	AC Real Power Scale Factor
Apparent Power					
40560	1	M_AC_VA	int16	Volt- Amps	Total AC Apparent Power (sum of active phases)
40561	1	M_AC_VA_A	int16	Volt- Amps	Phase A AC Apparent Power
40562	1	M_AC_VA_B	int16	Volt- Amps	Phase B AC Apparent Power
40563	1	M_AC_VA_C	int16	Volt- Amps	Phase C AC Apparent Power
40564	1	M_AC_VA_SF	int16	SF	AC Apparent Power Scale Factor
Reactive Power					
40565	1	M_AC_VAR	int16	VAR	Total AC Reactive Power (sum of active phases)
40566	1	M_AC_VAR_A	int16	VAR	Phase A AC Reactive Power
40567	1	M_AC_VAR_B	int16	VAR	Phase B AC Reactive Power
40568	1	M_AC_VAR_C	int16	VAR	Phase C AC Reactive Power
40569	1	M_AC_VAR_SF	int16	SF	AC Reactive Power Scale Factor
Power Factor					
40570	1	M_AC_PF	int16	%	Average Power Factor (average of active phases)
40571	1	M_AC_PF_A	int16	%	Phase A Power Factor
40572	1	M_AC_PF_B	int16	%	Phase B Power Factor
40573	1	M_AC_PF_C	int16	%	Phase C Power Factor
40574	1	M_AC_PF_SF	int16	SF	AC Power Factor Scale Factor
Accumulated Energy					
Real Energy					
40575	2	M_Exported	uint32	Watt- hours	Total Exported Real Energy
40577	2	M_Exported_A	uint32	Watt- hours	Phase A Exported Real Energy
40579	2	M_Exported_B	uint32	Watt- hours	Phase B Exported Real Energy
40581	2	M_Exported_C	uint32	Watt- hours	Phase C Exported Real Energy
40583	2	M_Imported	uint32	Watt- hours	Total Imported Real Energy
40585	2	M_Imported_A	uint32	Watt- hours	Phase A Imported Real Energy
40587	2	M_Imported_B	uint32	Watt- hours	Phase B Imported Real Energy
40589	2	M_Imported_C	uint32	Watt- hours	Phase C Imported Real Energy
40591	1	M_Energy_W_SF	int16	SF	Real Energy Scale Factor
Apparent Energy					
40592	2	M_Exported_VA	uint32	VA-hours	Total Exported Apparent Energy
40594	2	M_Exported_VA_A	uint32	VA-hours	Phase A Exported Apparent Energy
40596	2	M_Exported_VA_B	uint32	VA-hours	Phase B Exported Apparent Energy
40598	2	M_Exported_VA_C	uint32	VA-hours	Phase C Exported Apparent Energy
40600	2	M_Imported_VA	uint32	VA-hours	Total Imported Apparent Energy
40602	2	M_Imported_VA_A	uint32	VA-hours	Phase A Imported Apparent Energy
40604	2	M_Imported_VA_B	uint32	VA-hours	Phase B Imported Apparent Energy
40606	2	M_Imported_VA_C	uint32	VA-hours	Phase C Imported Apparent Energy
40608	1	M_Energy_VA_SF	int16	SF	Apparent Energy Scale Factor
Reactive Energy					
40610	2	M_Import_VARh_Q1	uint32	VAR-hours	Quadrant 1: Total Imported Reactive Energy
40612	2	M_Import_VARh_Q1A	uint32	VAR-hours	Phase A - Quadrant 1: Imported Reactive Energy
40614	2	M_Import_VARh_Q1B	uint32	VAR-hours	Phase B- Quadrant 1: Imported Reactive Energy

40616	2	M_Import_VARh_Q1C	uint32	VAR-hours	Phase C- Quadrant 1: Imported Reactive Energy
40618	2	M_Import_VARh_Q2	uint32	VAR-hours	Quadrant 2: Total Imported Reactive Energy
40620	2	M_Import_VARh_Q2A	uint32	VAR-hours	Phase A - Quadrant 2: Imported Reactive Energy
40622	2	M_Import_VARh_Q2B	uint32	VAR-hours	Phase B- Quadrant 2: Imported Reactive Energy
40624	2	M_Import_VARh_Q2C	uint32	VAR-hours	Phase C- Quadrant 2: Imported Reactive Energy
40626	2	M_Export_VARh_Q3	uint32	VAR-hours	Quadrant 3: Total Exported Reactive Energy
40628	2	M_Export_VARh_Q3A	uint32	VAR-hours	Phase A - Quadrant 3: Exported Reactive Energy
40630	2	M_Export_VARh_Q3B	uint32	VAR-hours	Phase B- Quadrant 3: Exported Reactive Energy
40632	2	M_Export_VARh_Q3C	uint32	VAR-hours	Phase C- Quadrant 3: Exported Reactive Energy
40634	2	M_Export_VARh_Q4	uint32	VAR-hours	Quadrant 4: Total Exported Reactive Energy
40636	2	M_Export_VARh_Q4A	uint32	VAR-hours	Phase A - Quadrant 4: Exported Reactive Energy
40638	2	M_Export_VARh_Q4B	uint32	VAR-hours	Phase B- Quadrant 4: Exported Reactive Energy
40640	2	M_Export_VARh_Q4C	uint32	VAR-hours	Phase C- Quadrant 4: Exported Reactive Energy
40642	1	M_Energy_VAR_SF	int16	SF	Reactive Energy Scale Factor
Events					
40643	2	M_Events	uint32	Flags	See M_EVENT_ flags. 0 = nts.

Appendix A – Supported MODBUS Request Methods

SolarEdge has implemented two methods of the MODBUS request procedure:

- MODBUS request with explicit register addressing - supported by all communication board CPU versions. For example:
 - Tx: 01 03 9C 40 00 7A EB AD – Read 122 registers starting at address 40001.
 - Rx: 01 03 F4 53 75 ... [Registers data] ... FF FF 12 1B
- MODBUS request without explicit addressing – supported by communication board CPU version 2.478 and above. For example:
 - Tx: 01 03 00 00 00 7A C4 29 – Read 122 registers starting at offset 0.
 - Rx: 01 03 F4 53 75 6E 53 ... [Registers data] ... FF FF AE DB

Appendix B – Response Time Information

When directly connected through either the same RS485 bus or Ethernet, the response time of an inverter is *<100ms per inverter @115200bps*.

Inverters with CPU firmware versions support a response time of 1 second, regardless of the number of inverters:

- Inverters with LCD or Commercial Gateway – 3.226x-3.2299, 3.245x and above
- Inverters with SetApp configuration – 4.4.5x and above

When connected through a Commercial Gateway, the response delay through the Commercial Gateway can be as much as $N*100[ms]+60[ms]$, where:

- N is the number of slave inverters on the bus
- $100ms$ is max slot time per slave in the SolarEdge bus
- $60ms$ is a constant delay for MODBUS packet assuming 115200bps.

The timeout delay per slave is the sum of:

- $N*100 [ms]$ - SolarEdge bus delay of N slaves, assuming each inverter transmits one SolarEdge telemetry and one full MODBUS response per grant slot.
- $256 * 10000/Baud\ rate [ms]$ - at least one full MODBUS packet over the MODBUS link, and limited to a minimum of 60ms (hardcoded).

For example, the timeout delay of a bus of 10 slaves and 115200 bps MODBUS link is: $1000 [ms] + 60 [ms]$.

Part of the slot is also consumed by the slave inverters transmitting SolarEdge telemetries at the same time.

Consider the following if trying to reduce delays when a Commercial Gateway is installed:

- Waiting for a response is part of the MODBUS definition, and this is limiting the bandwidth.
- Multiple retries may result in multiple replies, as the inverters receive all the MODBUS commands, but the SolarEdge bus topology delays the response. In this case, implementing a no-response-expected MODBUS command may balance between performance and reliability, as:
 - Inverters can be controlled with no delay except for the fixed 60ms per inverter (since a response is not expected).
 - An ACK from the inverter is not expected and the measured power from the meter is used as the feedback loop.
 - The responses from all the inverters are received in an $Nx100ms$ timeframe, which can be used for a sanity check.
 - If you try 0 [ms] timeout, expect the timeout to occur intentionally and disregard it.
- If you use MODBUS-over-SolarEdge with MODBUS replies, consider lower rates.

Appendix C – Encoding and Decoding 32-bit Values in Modbus

In Modbus, 32-bit values span two registers. This appendix explains how to encode and decode these registers correctly.

Since 32-bit values span two registers, they must be written in a single transaction of Write Multiple Registers (Function code 10) and not two consecutive Write Single Register (Function code 06) transactions.

32-bit Unsigned Integer (uint32)

Read Request

	Unit ID	Function	Address	Register Amount	
Request	01	03 (Read Holding Registers)	F604	00 02	
	Unit ID	Function	Address	Reg[0]	Reg[1]
Response	01	03 (Read Holding Registers)	F604	00 A0	00 00
Decoding Data	First register (0xF604) stores the least significant bytes: 0x00A0. Second register (0xF605) stores the most significant bytes: 0x0000. Decoded value: 0x0000 0x00A0 = 160				

Write Request

	Unit ID	Function	Address	Register Amount	Byte Count	Reg[0]	Reg[1]
Request	01	10 (Write Multiple Registers)	F6 04	00 02	04	09 61	00 55
	Unit ID	Function	Address	Register Amount			
Response	01	10 (Write Multiple Registers)	F6 04	00 02			
Encoding Data	New value: 5572961 (0x00550961) First register (0xF604) will store the least significant bytes: 0x0961. Second register (0xF605) will store the most significant bytes: 0x0055.						

32-bit Single Precision Floating Point (float32)

Read Request

	Unit ID	Function	Address	Register Amount	
Request	01	03 (Read Holding Registers)	F606	00 02	
	Unit ID	Function	Address	Reg[0]	Reg[1]
Response	01	03 (Read Holding Registers)	F606	CC CD	43 8E
Decoding Data	First register (0xF606) stores the least significant bytes: 0xCCCC. Second register (0xF607) stores the most significant bytes: 0x438E. Decoded value: 0xCCCC 0x438E = 285.6				

Write Request

	Unit ID	Function	Address	Register Amount	Byte Count	Reg[0]	Reg[1]
Request	01	10 (Write Multiple Registers)	F6 06	00 02	04	19 9A	43 91
	Unit ID	Function	Address	Register Amount			
Response	01	10 (Write Multiple Registers)	F6 06	00 02			
Encoding Data	New value: 290.2 (0x4391199A) First register (0xF606) will store the least significant bytes: 0x199A. Second register (0xF607) will store the most significant bytes: 0x4391.						