

# **MODBUS Protocol**

# **Application Note**

Tx1 and Tx3 Series

### Modbus Protocol- Application Note -Tx1 and Tx3 Series



# Contents

1	Introduction	2
2	Configuration	3
2.1	Physical Connection	3
2.2	GUI Setting	3
2.3	Restricted write access	3
3	Modbus Register Reading & Writing	4
3.1	Function Code	4
3.2	An Example of Request and Response	4

3.3	Data Types4
3.4	Modbus UDP support4
4	Register Map5
4.1	Scaling factors5
4.2	SunSpec register map5
5	Register description6
5.1	Common Block (Device ID001)6
6	References7

# **1** Introduction

This document describes the general aspects of the MODBUS protocol of the KACO string inverter series. The inverters support a subset of data models according to the SunSpec specification. For a detailed description of particular models refer to [8]. In this document the supported subset is highlighted.

Besides that KACO supports some vendor specific models which will be described in [9].

### Supported MODBUS protocols (legacy devices with local GUI)

- Modbus TCP/UDP

### Supported MODBUS protocols (new devices with dedicated web interface)

- Modbus TCP/UDP
- Modbus RTU

### **Supported Inverter Model**

- blueplanet TL1/TL3 series
- Powador TL3 series

### Modbus Protocol- Application Note -



### Tx1 and Tx3 Series

### Supported SW Version

Inverter Family	SW Version	Supported Models Device ID)	Supported Registers	Activation in HMI / WEBGUI	Comment	
blueplanet TL3	V2.02 or higher	Read only invertor				
Powador TL3	V2.10 or higher	Read only inverter models 001, 102,	-	Switch on/off all inverter models	First basic implementation	
blueplanet TL1	V3.00 or higher	103				
blueplanet TL3	V3,22 or higher		<b>122</b> (TmSrc)			
Powador TL3	-	001, 102, 103, <b>122,</b> <b>123</b>	Device; <b>123</b> (WMax LimPct)	Switch on/off all inverter models		
blueplanet TL1	V3.26 or higher					
blueplanet TL3	V4.00 or higher	001, 102, 103, 122,		- Switch on/off only read only registers	Support some	
Powador TL3	V4.00 or higher	123, <b>112, 113, 129,</b> <b>130, 135, 136, 160</b>		- Switch on/off read	inverter control models	
blueplanet TL1	V4.00 or higher			and write registers		

To see all supported models and registers of this software version, see the attached excel charts:

SunSpec-Information-Model-Reference.xlsx

SunSpec-Information-Model-Reference-Kaco.xlsx (not for TL1)

# 2 Configuration

# 2.1 Physical Connection

In order to use the MODBUS features the device must be connected to Ethernet, or to a RS485 bus respectively. For more detailed information, please refer to the inverter's Operating instruction in chapter "Connecting the interfaces".

# 2.2 GUI Setting

It is necessary to activate the MODBUS/SunSpec protocol via the corresponding menus in local GUI or WEBGUI. For US series inverters the MODBUS/SunSpec protocol is activated by default. The MODBUS/TCP Port is set to 502 by default.

The write access to the MODBUS registers has to be activated separately in the inverter MODBUS/SunSpec protocol menu. If not, only read access is permitted for security reasons.

For more detailed information, please refer to the inverter's Operating instruction in chapter "Menu structure".

### 2.3 Restricted write access

Some SunSpec settings have to be stored permanently on the inverters internal FLASH memory, so they will be persistent over a power cycle.



### NOTE

These values must NOT be written periodically, because this would destroy the inverters internal FLASH memory. Values which are NOT to be written periodically are marked by a red RW field in the SunSpec model tables below.

Example									
2	0	1	RW	ActCrv	Unit16	-	-	Index of active curve.	1-4
								0=no active curve.	

Tx1 and Tx3 Series



# 3 Modbus Register Reading & Writing

# 3.1 Function Code

You can use two following MODBUS function codes.

- 03 (0x03) Read holding registers
- 06 (0x06) Write single holding register
- 16 (0x10) Write multiple holding registers

### 3.2 An Example of Request and Response

This is an example of request and response for reading 8 registers starting from address 40001.

Request	Request										
	MBAP			PDU							
Data (Hex)	00 00	00 00	00 06	01	03	9C 40	00 08				
Field Name	Trans- action ID	Protocol ID	Length	Unit Identifier	Function Code	*Starting Address	# of Registers				

\* The address of response is always 1 less than the address of register map in accordance with the MODBUS specification.

Response	Response									
	MBAP			PDU						
Data (Hex)	00 00	00 00	00 13	01	03	10	53 75 6e 53 00 01 00 42 4b 41 43 4f 20 4e 65 77			
Field Name	Trans- action ID	Protocol ID	Length	Unit Identifier	Function Code	Byte Count	Register Values			

The field "Unit Identifier (UID)" in the request is only supported for the new device generation, where it will be used to address one or more auxiliary devices (e.g. String combiner), connected to the device via an RS485 bus.

For legacy devices it will simply be ignored in the context of the TCP protocol.

When using the UDP option, the Unit Identifier has to be set to zero. In the corresponding response, the UID from request will returned.

### 3.3 Data Types

This MODBUS Protocol Data Type follows the one of SunSpec Specifications [8], [9].

- uint32, uint16, int16
- string, bitfield32, enum16

For more detailed information, please refer to SunSpec Specifications [8] in Chapter "Standard Data Formats".

### **3.4 Modbus UDP support**

Modbus UDP is supported by the inverters as of packet version 4.0 and higher. The Modbus UDP port is the same as the Modbus TCP port (defaults to port 502).

The support for Modbus UDP is restricted to write only Modbus commands. Therefore it has to be assured that Modbus write access is enabled in the inverter menu. The commands are being processed, but no answer is send to the Modbus client. Read requests have to be transferred via Modbus TCP.

In Modbus UDP unicast and broadcast write requests are supported by the inverters.

### Tx1 and Tx3 Series



# 4 Register Map

# 4.1 Scaling factors

SF in below table is an abbreviation of "Scale Factor". You can calculate a real value of specific address using SF value, received value via MODBUS and following equation.

#### {Real Value} = {Received value via MODBUS} \* 10<sup>(SF)</sup>

### Example:

Address offset 29 and 30 mean DC voltage and the DCV-SF value is -1. If a received value via MODBUS is 5042, DC voltage is as follow.

### {DC Voltage} = (5042) \* 10<sup>(-1)</sup> = 504.2 Volt

The way to use Scale factor is the same of SunSpec specification.

## 4.2 SunSpec register map

The register map must start with the SunSpec ID, indicating that the following registers are Modbus/SunSpec registers. The base register address is 40001, and has the following representation:

	Address Start / End		R/W	Name	Туре	Units	SF	Description	Value Range
40001	40002	2	R	SunSpec ID	uint32	-	-	Uniquely identifies this as a SunSpec Modbus Map	0x53756e53



### NOTE

To read the base register 40001, use the address 0x9C40 (=40000) on the wire. [10]

After this SunSpecID the supported SunSpec models follow one by one. To retrieve the offsets for the supported SunSpec models in the register map, the headers for each model have to be parsed until a specific "END\_OF\_MAP" model is found. This model has the following content:

Addr. Offset	Block Offset	Size	R/W	Name	Туре	Units	SF	Description	Value Range
0	-	1	R	SunSpec DID	Uint16	-	-	End of Register map	0xFFFF
1	-	1	R	SunSpec Length	Unit16	-	-	Model length	0

#### Example:

The SunSpec ID (0x53756e53 ="SunS") starts at register 40001.

Therefore the first SunSpec model starts at register 40003.

Assuming the first model is SunSpec Common Model (DID 1 and Length 66) the address of the next model can be calculated as follows::

### 40003 (Model offset) + 66 (Model length) = 40069 (Next model register)

The next model starts then at register 40069, and the header may be retrieved from there.

This method to enumerate all supported models can be repeated, until the "END\_OF\_MAP" model with DID 0xFFFF is found.

To retrieve an explicit value from a certain model, the offset of that value has to be added to the models offset retrieved in the manner above.

### Modbus Protocol- Application Note -

### Tx1 and Tx3 Series





### NOTE

Again - keep in mind, that when you refer to a specific address in a model you've to use the <register\_address -1> on the wire!

# **5** Register description

For a detailed description of particular models / registers refer to [8] and [9]

### 5.1 Common Block (Device ID001)

The register description for "Common Block (DID 001) is only an example may not reflect the current implementation.

Addr. Offset	Block Offset	Size	R/W	Name	Туре	Units	SF	Description	Value Range
0	-	1	R	SunSpec DID	unit16	-	-	SunSpec Common Model	001 (dec)
1	-	1	R	SunSpec Length	uint16	-	-	Model Length	66 (dec)
2	0	16	R	Manufacturer	string	-	-		"KACO new energy"
18	16	16	R	Model	string	-	-	KACO inverter name	e.g. "Powador 39.0 TL3"
34	32	8	R	Options	string	-	-	Data logger ID-String	e.g. "390TL"
42	40	8	R	Version	string	-	-	The packet version of the currently installed software	e.g. "V2.10"
50	48	16	R	Serial Number	string	-	-	Serial number set during production process	e.g. "39.0TL011 23456"
66	64	1	-	Device Address	uint16	-	-	Not implemented	-
67	65	1	R	-	pad	-	-	Force even alignment	0

### **Tx1 and Tx3 Series**



# **6** References

#### **Modbus Organization**

- [1] <u>http://www.modbus.org</u>
- [2] Modbus\_Application\_Protocol\_V1\_1b3.pdf
- [3] Modbus\_Messaging\_Implementation\_Guide\_V1\_0b.pdf

#### SunSpec Specification

- [4] <u>http://www.sunspec.org</u>
- [5] SunSpec-Alliance-Specification-Common-Models-v1.5.pdf
- [6] SunSpec Alliance Specification Inverter Models v1.1.pdf
- [7] SunSpec Information Models 12041.pdf (SunSpec Information Model Specification SunSpec Alliance Interoperability Specification V1.8)

#### SunSpec Models

- [8] SunSpec-Information-Model-Reference.xlsx
- [9] SunSpec-Information-Model-Reference-Kaco.xlsx



Carl-Zeiss-Straße 1 · 74172 Neckarsulm · Germany · Phone +49 7132 3818-0 · Fax +49 7132 3818-703 · info@kaco-newenergy.de · www.kaco-newenergy.de